



Product Service

# Attestation of Conformity

No. N8A 115896 0027 Rev. 02

**Holder of Attestation:** Yingli Energy Development Co., LTD.  
No.3399, Chaoyang North Road  
071051 Baoding, Hebei  
PEOPLE'S REPUBLIC OF CHINA

**Product:** Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono-crystalline Silicon Photovoltaic (PV) Modules

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 882162407303

**Date,** 2024-08-29

( Xinlian LUO )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 115896 0027 Rev. 02

## Model(s):

With half-cut (bifacial) N-type mono c-Si cell (under STC)

YLxxxCF78 e/2 (xxx=585-650, in steps of 5, 156 cells)

YLxxxCF72 e/2 (xxx=540-600, in steps of 5, 144 cells)

YLxxxCF66 e/2 (xxx=495-545, in steps of 5, 132 cells)

YLxxxCF60 e/2 (xxx=450-495, in steps of 5, 120 cells)

YLxxxCF54 e/2 (xxx=405-445, in steps of 5, 108 cells)

YLxxxCF72 g/2 (xxx=580-605, in steps of 5, 144 cells)

YLxxxCF54 g/2 (xxx=435-450, in steps of 5, 108 cells)

YLxxxCF72 h/2 (xxx=590-615, in steps of 5, 144 cells)

YLxxxCF54 h/2 (xxx=445-460, in steps of 5, 108 cells)

YLxxxCF66 i/2 (xxx=590-630, in steps of 5, 132 cells)

YLxxxCF48 i/2 (xxx=430-455, in steps of 5, 96 cells)

YLxxxCF66 f/2 (xxx=685-720, in steps of 5, 132 cells)

YLxxxCF60 f/2 (xxx=625-655, in steps of 5, 120 cells)

With half-cut (bifacial) N-type mono c-Si cell (under BNPI)

YLxxxCF78 e/2 (xxx=648, 654, 660, 665, 671, 676, 682, 687, 693, 698, 704, 709, 715, 721, 156 cells)

YLxxxCF72 e/2 (xxx=598, 604, 610, 615, 621, 626, 632, 637, 643, 648, 654, 659, 665, 144 cells)

YLxxxCF66 e/2 (xxx=549, 554, 560, 565, 571, 576, 582, 587, 593, 598, 604, 132 cells)

YLxxxCF60 e/2 (xxx=499, 504, 510, 516, 521, 526, 532, 538, 543, 549, 120 cells)

YLxxxCF54 e/2 (xxx=449, 455, 460, 465, 471, 477, 482, 488, 493, 108 cells)

YLxxxCF72 g/2 (xxx=643, 648, 654, 659, 665, 670, 144 cells)

YLxxxCF54 g/2 (xxx=482, 488, 493, 108 cells)

YLxxxCF72 h/2 (xxx=654, 659, 670, 676, 682, 144 cells)

YLxxxCF54 h/2 (xxx=493, 499, 504, 510, 108 cells)

YLxxxCF66 i/2 (xxx=654, 659, 665, 670, 676, 682, 692, 698, 132 cells)

YLxxxCF48 i/2 (xxx=477, 482, 488, 493, 499, 504, 96 cells)

YLxxxCF66 f/2 (xxx=759, 765, 770, 776, 782, 787, 792, 798, 132 cells)

YLxxxCF60 f/2 (xxx=693, 698, 704, 709, 715, 721, 726, 120 cells)

xxx is standing for rated output power in Wp

## Parameters:

Safety Class: Class II

Max. System Voltage: 1500V DC

Construction: Framed, with Junction box, cable and connector.

Fire Safety Class: Class A or C according to UL790

## Tested according to:

EN 61730-1:2018

EN 61730-2:2018

EN IEC 61730-1:2018/AC:2018-06

EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.